DC Power Project Q & A Submission

1. Q: The bid form does not have a line for required ancillary materials (ground cable, anchors, top support materials) which line of the bid form should those materials be added to?
    a. Please see attached new bid cost form Exhibit A revised 11/23/2026. The original bid form has been removed. This will be considered Addendum #1 to the bid.

2. Q: Line 13 on the bid documents pertains to 30amp AC circuit installation. it was noted on the walk that AC power will be provided at the sites by the county, is this line still applicable or should it be omitted?
    a. The circuit is provided to the wall or ceiling near the equipment. Bidder is responsible for the termination of this circuit including the twist lock style connector or wire feed to DC equipment rack.

3. Q: Can only one document be uploaded at a time? I have (4) documents to upload per site
    a. Your documents should be packaged together in a compressed “zipped” file.

4. For each site, where will the Trimm Panel(s) be located and how many feet is that from the new power plant location.
    a. A rough floor plan document has been posted to the IFB site for estimated location of the equipment. Each site will have electrical circuits ran from an electrical panel to a location on the wall nearest the NEW DC rack install point as shown on the rough floor plan document.